

Universal Industrial Gateway Release Notes – Version 2.00.106

12/22/2021

- NEW: Security updates
- NEW: UI will attempt to reconnect after a planned reboot from the Operations page
- FIXED: Device export now includes Slot Number
- FIXED: Trace Files now deleted after 10 days
- FIXED: Unit name and IP address now included in diagnostics, comments.txt file
- FIXED: Version block now included in diagnostics file
- FIXED: When reading a tag of a smaller data type than the data type configured in the Gateway, the unused portion is set to zero
- DOCUMENTATION: S7-1200 and S7-1500 Modbus tag values appear in word-swapped order in Live Tag Viewer